



BRANZ Appraised
Appraisal No. 1098 [2019]

**PREMIER POLYESTER
UNDERFLOOR
INSULATION**



Appraisal No. 1098 [2019]

BRANZ Appraisals

Technical Assessments of products for building and construction.



PIL Group Ltd

183 Great South Road
Ngaruawahia 3720
Tel: 07 282 1184

Email: sales@pilgroup.co.nz

Web: www.pilgroup.co.nz



BRANZ

1222 Moonshine Rd,
RD1, Porirua 5381
Private Bag 50 908
Porirua 5240,
New Zealand
Tel: 04 237 1170
branz.co.nz



Product

1.1 Premier Polyester Underfloor Insulation is manufactured from thermally bonded polyester fibres, for use in suspended timber framed floors.

Scope

2.1 Premier Polyester Underfloor Insulation has been appraised for use as a thermal insulating material for timber framed floors in new or existing domestic and commercial buildings.

Building Regulations

New Zealand Building Code (NZBC)

3.1 In the opinion of BRANZ, Premier Polyester Underfloor Insulation if designed, used, installed and maintained in accordance with the statements and conditions of this Appraisal, will meet or contribute to meeting the following provisions of the NZBC:

Clause B2 DURABILITY: Performance B2.3.1 [b] not less than 15 years and B2.3.1 [c] 5 years. Premier Polyester Underfloor Insulation meets these requirements. See Paragraph 8.1.

Clause F2 HAZARDOUS BUILDING MATERIALS: Performance F2.3.1. Premier Polyester Underfloor Insulation meets this requirement and will not present a health hazard to people.

Clause H1 ENERGY EFFICIENCY: Performance H1.3.2. E. Premier Polyester Underfloor Insulation will contribute to meeting these requirements. See Paragraph 14.1 and 14.2.

Technical Specification

4.1 Premier Polyester Underfloor Insulation is manufactured from non-woven thermally bonded polyester fibers. The fibres are blended, carded, thermally bonded and formed into blankets. Premier Polyester Underfloor Insulation is available as set out in Table 1.

Table 1: Premier Polyester Underfloor Insulation

| R-value | Nominal Thickness [mm] | Width* [mm] | Length [mm] | Density [g/m ³] |
|---------|------------------------|--------------------------|-------------|-----------------------------|
| R1.5 | 100 | 450 or 510 or 600 or 650 | various | 7.5 |
| R1.8 | 115 | 450 or 510 or 600 or 650 | various | 7.8 |

*PIL Group Ltd provides additional to the listed width customised orders. These must be to the same R-value, thickness and density requirements as the products above.



- 4.2 Premier Polyester Underfloor Insulation is white in colour and is packaged in black plastic compression bags with labelling in compliance with AS/NZS 4859.1.
- 4.3 Accessories used with Premier Polyester Underfloor Insulation, which are supplied by the insulation installer, are staples suitable to fix insulation.

Handling and Storage

- 5.1 Premier Polyester Underfloor Insulation must be stored under cover, away from direct sunlight and in dry conditions. Heavy objects must not be stacked on the packs. The packs must be stored in an orientation that avoids excessive compression of the product.
- 5.2 In general, insulation products are sensitive to the length of time they are stored under compression packaging. Product that does not recover to its nominal thickness may not achieve the stated R-value.

Technical Literature

- 6.1 Refer to the Appraisals listing on the BRANZ website for details of the current Technical Literature for Premier Polyester Underfloor Insulation. The Technical Literature must be read in conjunction with this Appraisal. All aspects of design, use, installation and maintenance contained in the Technical Literature and within the scope of this Appraisal must be followed.

Design Information

General

- 7.1 Premier Polyester Underfloor Insulation is intended for use as a thermal insulation to meet the requirements of the NZBC. Premier Polyester Underfloor Insulation R-values of 1.5 m²C/W and 1.8 m²C/W are designed to meet the minimum schedule method R-values of NZBC Verification Method H1/VM1 or NZBC Acceptable Solution H1/AS1. Greater construction R-values can be achieved where specific design is used. For construction R-values, refer to the BRANZ House Insulation Guide. Product R-values and dimensions are given in Table 1.
- 7.2 Premier Polyester Underfloor Insulation thermal resistance [R-value] has been determined by testing to AS/NZS 4859.1, which is an acceptable method in NZBC Acceptable Solution H1/AS1.
- 7.3 Premier Polyester Underfloor Insulation is designed to be fitted between joists and stapled in place. Fixing centres vary with the joist centres and the manufacturer's instructions must be followed.
- 7.4 Where the subfloor area is subject to wind such as in pole houses, or the subfloor does not have a closed perimeter, e.g. solid concrete, masonry ring foundation or a subfloor that is enclosed with a sheet material, the insulation must be protected with a suitable lining material.
- 7.5 The building envelope must be constructed to ensure that the insulation remains dry during installation and throughout the life of the building.
- 7.6 The clearance requirements for heating appliances and downlights must be met and reference made to the manufacturer's instructions and NZS 4246. See Paragraphs 10.1 - 10.3.

Durability

- 8.1 Assessment of durability to meet the NZBC is based on difficulty to access and replacement, and the ability to detect failure of Premier Polyester Underfloor Insulation both during normal use and maintenance of the building.

Serviceable Life

- 8.2 Where the building is maintained so that provisions of NZBC Clauses E2 and E3 are met and the insulation is not crushed or exposed to conditions that will diminish its thermal performance, then Premier Polyester Underfloor Insulation is expected to have a serviceable life of at least 15 years. Support accessories must also be selected according to the required serviceable life.



Maintenance

- 9.1 Insulation that has become damp must be removed and the cause of dampness repaired. Cavities must be clean and dry before replacing with new Premier Polyester Underfloor Insulation. NZS 4246 gives guidance on thermal insulation maintenance due to water damage.

Prevention of Fire Occurring

- 10.1 Separation or protection must be provided to Premier Polyester Underfloor Insulation from heat sources such as fire places, heating appliances, flues, chimneys and recessed luminaires. Refer to Part 7 of NZBC Acceptable Solution C/AS1, C/AS2 and NZBC Verification Method C/VM1.

Downlights

- 10.2 Recessed luminaires shall be of type and installed in accordance with NZBC Acceptable Solutions C/AS1 or C/AS2, Section 7.4.
- 10.3 Insulation materials must maintain a clearance of 100 mm to undefined recessed luminaires in existing buildings.

Control of Internal Fire and Smoke Spread

- 11.1 The complete ceiling system, including the surface lining product enclosing the Premier Polyester Underfloor Insulation from the adjacent occupied space, must achieve the Group Number for internal surface finish requirements as specified in the relevant NZBC Acceptable Solution C/AS1 and C/AS2.

External Moisture

- 12.1 The total building envelope must be weathertight and comply with the requirements of NZBC Clause E2 to ensure that the insulation remains dry in use.
- 12.2 The moisture content of the construction materials at the time of installing and enclosing the insulation must meet the requirements of NZBC Acceptable Solution E2/AS1 Paragraph 10.2(a), or a lower moisture content if required by the flooring manufacture.

Internal Moisture

- 13.1 Building must provide an adequate combination of thermal resistance, ventilation and space temperature to all habitable spaces, bathrooms, laundries and other spaces where moisture may be generated or may accumulate. This does not apply to Communal Non-residential, Commercial, Industrial, Outbuildings or Ancillary buildings.

Energy Efficiency

- 14.1 Premier Polyester Underfloor Insulation will contribute to meeting the requirements of NZBC Clause H1 Performance H1.3.1(a) and H1.3.2 E by compliance with NZBC Verification Method H1/VM1 or NZBC Acceptable Solution H1/AS1.
- 14.2 Premier Polyester Underfloor Insulation R-values have been determined by BRANZ testing to AS/NZS 4859.1 and are given in Table 1.

Installation Information

Installation Skill Level Requirements

- 15.1 Installation of Premier Polyester Underfloor Insulation must be completed by an installer with an understanding of insulation installation.

General

- 16.1 Installation of Premier Polyester Underfloor Insulation must be in accordance with the Technical Literature, Installation Instructions and this Appraisal. NZS 4246 should be used as a guide for installing insulation in residential buildings.
- 16.2 Premier Polyester Underfloor Insulation must be installed only when the building is enclosed and when the construction materials have achieved the required maximum moisture content or less.



- 16.3 Premier Polyester Underfloor Insulation must be released from the packaging and allowed to re-loft prior to installation. The time to loft will depend upon the length of time the product has been packaged and stored.
- 16.4 Premier Polyester Underfloor Insulation is designed to be a minimum of 40 mm wider than the joist cavity and excess material should be folded 20 mm down on each side. The insulation must be installed hard against the floor, ends neatly butted and the ends of joist runs sealed off so that the potential for gaps and convective heat loss is reduced. It must be stapled along the length of the blanket at intervals of 100 mm. Premier Polyester Underfloor Insulation Technical Literature must be referred to for installation details.
- 16.5 A minimum of 100 mm gap must be maintained between Premier Polyester Underfloor Insulation and plumbing, pipe work fittings. This gap will also ensure that there is adequate access for servicing.
- 16.6 The clearance requirements for heating appliances, light fittings, and downlights must be followed. Refer also to NZS 4246.

Inspection

- 16.7 The Technical Literature, this Appraisal and NZS 4246 must be referred to during the inspection of Premier Polyester Underfloor Insulation.

Health and Safety

- 17.1 Refer to the Technical Literature and NZS 4246 for guidance on health and safety requirements such as personal protective clothing and installation hazard assessment.



Basis of Appraisal

The following is a summary of the technical investigations carried out:

Tests

- 18.1 BRANZ has carried out thermal resistance testing of Premier Polyester Underfloor Insulation in accordance with AS/NZS 4859.1.

Other Investigations

- 19.1 An assessment of the durability of Premier Polyester Underfloor Insulation has been made by BRANZ technical experts.
- 19.2 The manufacturer's Technical Literature has been reviewed by BRANZ and found to be satisfactory.
- 19.3 Site inspections have been undertaken by BRANZ to assess the practicability of installation.

Quality

- 20.1 The manufacture of Premier Polyester Underfloor Insulation has been examined by BRANZ including methods adopted for quality control. Details of the manufacturing processes and quality and composition of the raw materials used were obtained and found to be satisfactory.
- 20.2 PIL Group Ltd is responsible for the quality of the product supplied.
- 20.3 Quality of installation of the product on site is the responsibility of the installer.
- 20.4 Quality of the maintenance of the building to ensure the insulation remains dry is the responsibility of the building owner.

Sources of Information

- AS/NZS 4859.1: 2018 Materials for the thermal insulation of buildings.
- NZS 4246: 2016 Energy efficiency - Installing bulk thermal insulation in residential buildings.
- BRANZ House Insulation Guide, Fifth Edition 2014.
- Ministry of Business, Innovation and Employment record of Amendments - Acceptable Solutions, Verification Methods and Handbooks.
- The Building Regulations 1992.



BRANZ Appraised
Appraisal No. 1098 [2019]

BRANZ Appraisal
Appraisal No. 1098 [2019]
9 December 2019

PREMIER POLYESTER
UNDERFLOOR INSULATION



In the opinion of BRANZ, **Premier Polyester Underfloor Insulation** is fit for purpose and will comply with the Building Code to the extent specified in this Appraisal provided it is used, designed, installed and maintained as set out in this Appraisal.

The Appraisal is issued only to **PIL Group Ltd**, and is valid until further notice, subject to the Conditions of Appraisal.

Conditions of Appraisal

1. This Appraisal:
 - a) relates only to the product as described herein;
 - b) must be read, considered and used in full together with the Technical Literature;
 - c) does not address any Legislation, Regulations, Codes or Standards, not specifically named herein;
 - d) is copyright of BRANZ.
2. **PIL Group Ltd**:
 - a) continues to have the product reviewed by BRANZ;
 - b) shall notify BRANZ of any changes in product specification or quality assurance measures prior to the product being marketed;
 - c) abides by the BRANZ Appraisals Services Terms and Conditions;
 - d) warrants that the product and the manufacturing process for the product are maintained at or above the standards, levels and quality assessed and found satisfactory by BRANZ pursuant to BRANZ's Appraisal of the product.
3. BRANZ makes no representation or warranty as to:
 - a) the nature of individual examples of, batches of, or individual installations of the product, including methods and workmanship;
 - b) the presence or absence of any patent or similar rights subsisting in the product or any other product;
 - c) any guarantee or warranty offered by **PIL Group Ltd**.
4. Any reference in this Appraisal to any other publication shall be read as a reference to the version of the publication specified in this Appraisal.
5. BRANZ provides no certification, guarantee, indemnity or warranty, to **PIL Group Ltd** or any third party.

For BRANZ

Chelydra Percy

Chief Executive

Date of Issue:

9 December 2019