



BRANZ Appraised

Appraisal No. 638 [2019]

A-LIGN® RUSTICATED WEATHERBOARD CAVITY CLADDING SOLUTION

Appraisal No. 638 [2019]

This Appraisal replaces BRANZ Appraisal No. 638 [2009]



BRANZ Appraisals

Technical Assessments of products for building and construction.



Claymark Limited

PO Box 21 702
Henderson
Auckland

Tel: 09 836 8450

Fax: 09 836 8453

Web: www.claymark.co.nz



BRANZ

BRANZ

1222 Moonshine Rd,
RD1, Porirua 5381
Private Bag 50 908

Porirua 5240,
New Zealand

Tel: 04 237 1170

branz.co.nz

Product

- 1.1 The A-lign® Rusticated Weatherboard Cavity Cladding Solution is a cavity-based external wall cladding solution for residential and light commercial type buildings where domestic construction techniques are used.
- 1.2 The solution consists of horizontally fixed A-lign® rusticated timber weatherboards, A-lign® timber cavity battens, flashings and accessories and is finished with two coats of 100% premium acrylic house paint.
- 1.3 The solution incorporates a primary and secondary means of weather resistance [first and second line of defence] against water penetration by separating the cladding from the external wall frame with a nominal 20 mm drained cavity.

Scope

- 2.1 The A-lign® Rusticated Weatherboard Cavity Cladding Solution has been appraised as an external horizontally fixed wall cladding solution for buildings within the following scope:
 - the scope limitations of NZBC Acceptable Solution E2/AS1, Paragraph 1.1; and,
 - constructed with timber framing complying with the NZBC; and,
 - with a risk score of 0-20, calculated in accordance with NZBC Acceptable Solution E2/AS1, Table 2; and,
 - situated in NZS 3604 Wind Zones up to, and including Extra High.
- 2.2 The A-lign® Rusticated Weatherboard Cavity Cladding Solution has also been appraised for weathertightness and structural wind loading when used as an external horizontally fixed wall cladding solution for buildings within the following scope:
 - the scope limitations of NZBC Acceptable Solution E2/AS1, Paragraph 1.1; and,
 - constructed with timber framing complying with the NZBC; and,
 - situated in specific design wind pressures up to a maximum design differential ultimate limit state [ULS] of 2.5 kPa.
- 2.3 The A-lign® Rusticated Weatherboard Cavity Cladding Solution is appraised for use with aluminium window and door joinery that is installed with vertical jambs and horizontal heads and sills. *[The Appraisal of the A-lign® Rusticated Weatherboard Cavity Cladding Solution relies on the joinery meeting the requirements of NZS 4211 for the relevant Wind Zone or wind pressure.]*



Building Regulations

New Zealand Building Code (NZBC)

3.1 In the opinion of BRANZ, the A-lign® Rusticated Weatherboard Cavity Cladding Solution, if designed, used, installed and maintained in accordance with the statements and conditions of this Appraisal, will meet the following provisions of the NZBC:

Clause B1 STRUCTURE: Performance B1.3.1, B1.3.2 and B1.3.4. The A-lign® Rusticated Weatherboard Cavity Cladding Solution meets the requirement for loads arising from self-weight, wind, impact and creep [i.e. B1.3.3 (a), (h), (j) and (q)]. See Paragraphs 9.1 – 9.4.

Clause B2 DURABILITY: Performance B2.3.1 (b), 15 years, B2.3.1 (c) 5 years and B2.3.2. The A-lign® Rusticated Weatherboard Cavity Cladding Solution meets these requirements. See Paragraph 10.1.

Clause E2 EXTERNAL MOISTURE: Performance E2.3.2. The A-lign® Rusticated Weatherboard Cavity Cladding Solution meets this requirement. See Paragraphs 14.1 -14.5.

Clause F2 HAZARDOUS BUILDING MATERIALS: Performance F2.3.1. The A-lign® Rusticated Weatherboard Cavity Cladding Solution meets this requirement and will not present a health hazard to people.

Technical Specification

4.1 Solution components and accessories supplied by Claymark Limited are as follows:

A-lign® Weatherboards

- The A-lign® rusticated weatherboards are manufactured from New Zealand Radiata pine. They are finger-jointed in accordance with the requirements of AS 5069 and treated to Hazard Class H3.1. The weatherboards are supplied factory coated with a two coat system of a premium timber primer and undercoat on the front and back face and top and bottom edges, and are beige in colour.
- The weatherboard profiles are in accordance with BRANZ Bulletin 411. The weatherboards are 18 mm thick and are available 142 mm and 187 mm wide. They are supplied in 6.1 m and 7.2 m lengths [by arrangement].
- An 18 mm thick A-lign® rusticated base board is also available in 142 and 187 mm widths. They are supplied in 6.1 m and 7.2 m lengths [by arrangement].

Cavity Battens

- A-lign® structural cavity battens – 45 mm wide by 19 mm thick, clear grade, finger jointed Radiata pine treated to Hazard Class H3.1.

Accessories

- A-lign® boxed corners – 102 x 102 x 18 mm pre-made boxed corners supplied in 5.4 m lengths.
- A-lign® scribe – 18 mm wide pre-cut scribe with pencil edges supplied in 5.4 m lengths.
- A-lign® internal corner scribe – 27 x 27 mm pre-cut scribe with pencil edges supplied in 5.4 m lengths.
- A-lign® transition scribes – 42 x 27 mm and 66 x 18 mm pre-cut scribes with pencil edges supplied in 5.4 m lengths.
- A-lign® facing boards – 18 mm thick boards in widths of 42, 66, 90, 116, 138 and 185 mm. The facing boards are supplied in 5.4 m lengths.
- A-lign® rusticated scalloped filler mould – supplied in 5.4 m lengths.
- A-lign® weatherhead and sill mould – 42 x 30 mm, supplied in 5.4 m lengths.
- A-lign® eaves mould – 42 x 18 mm, supplied in 5.4 m lengths.

Note: All timber accessories are manufactured from finger jointed New Zealand Radiata pine treated to Hazard Class H3.1. The accessories are supplied factory coated with two coats of premium timber primer on the front and back face and top and bottom edges, and are beige in colour.

4.2 Accessories used with the A-lign® Rusticated Weatherboard Cavity Cladding Solution are:



- **Flashings supplied by Quickflash** – including external corner flashing, internal corner flashing, horizontal inter-storey joint flashing, sill flashing, window and door head flashing, balustrade and parapet saddle flashing and balustrade and parapet cap flashings. The flashings are available in galvanised steel, aluminium or stainless steel and are supplied in 3.0 m lengths. Refer to NZS 3604, Section 4 and NZBC Acceptable Solution E2/AS1, Table 20 for durability requirements.
- **Cavity vent strip supplied by Quickflash** – galvanised steel, aluminium or stainless steel, punched with 5 mm diameter holes or slots complying with NZBC Acceptable Solution E2/AS1, Paragraph 9.1.8.3. Available in 3.0 m lengths.
- **A-Lign® End Seal** – a solvent based zinc naphthenate treatment for the cut-ends of A-lign® weatherboards and accessories. A-lign® End Seal is supplied in aerosol spray cans.

4.3 Accessories used with the A-lign® Rusticated Weatherboard Cavity Cladding Solution which are supplied by the building contractor are:

- **Flexible wall underlay** – building paper complying with NZBC Acceptable Solution E2/AS1, Table 23, or breather-type membranes covered by a valid BRANZ Appraisal for use as wall underlays.
- **Flexible building underlay support** – polypropylene strap, 75 mm galvanised mesh, galvanised wire, or additional vertical battens for securing the flexible building underlay in place and preventing bulging of the bulk insulation into the drainage cavity. *[Note: mesh and wire galvanising must comply with AS/NZS 4534.]*
- **Rigid wall underlay** – Plywood or fibre cement sheet complying with NZBC Acceptable Solution E2/AS1, Table 23, or rigid sheathing covered by a valid BRANZ Appraisal for use as rigid air barrier systems.
- **Flexible sill and jamb flashing tape** – flexible flashing tapes complying with NZBC Acceptable Solution E2/AS1, Paragraph 4.3.11, or flexible flashing tapes covered by a valid BRANZ Appraisal for use around window and door joinery openings.
- **Window and door trim cavity air seal** – air seals complying with NZBC Acceptable Solution E2/AS1, Paragraph 9.1.6, or self-expanding, moisture cure polyurethane foam air seals covered by a valid BRANZ Appraisal suitable for use around window, door and other wall penetration openings.
- **Aluminium joinery head flashings** – as supplied by the joinery manufacturer or contractor.
- **Flexible sealant** – sealant complying with NZBC Acceptable Solution E2/AS1, or sealant covered by a valid BRANZ Appraisal for use as a weather sealing sealant for exterior use.
- **A-lign® structural cavity batten fixings** – 60 x 2.8 mm hot-dip galvanised or stainless steel ring shank jolt head hand driven nails or 64 x 2.8 mm stainless steel ring shank power driven nails.
- **A-lign® rusticated weatherboard fixings [to structural battens] for NZS 3604 Building Wind Zones up to, and including Very High** – 60 x 2.8 mm hot-dip galvanised or stainless steel ring shank jolt head nails.
- **A-lign® rusticated weatherboard fixings [to structural battens] for specific design wind pressures up to a design differential ultimate limit state (ULS) wind pressure of 2.5 kPa** – 75 x 3.15 mm hot-dip galvanised or stainless steel ring shank jolt head nails.
- **A-lign® boxed corner fixings** – 50 x 2.8 mm hot-dip galvanised or stainless steel ring shank jolt head nails.
- **A-lign® scriber and trim fixings** – 60 x 2.8 mm hot-dip galvanised or stainless steel ring shank jolt head nails.

[Note: Hot-dip galvanising must comply with AS/NZS 4680 and stainless steel fixings must be Grade 316.]

Paint System Specification



- 4.4 Finish paint systems are not supplied by Claymark Limited and have not been assessed by BRANZ and are therefore outside the scope of this Appraisal.
- 4.5 All exposed faces, including top edges at sills and all bottom edges of A-lign® weatherboards and accessories must be finished with at least two coats of an exterior grade latex acrylic paint complying with any of Parts 7, 8, 9 or 10 of AS 3730.

[Note: For A-lign® rusticated weatherboards, Claymark Limited recommends using paint with a colour which has a Light Reflective Value (LRV) of greater than or equal to 45%]

Handling and Storage

- 5.1 Handling and storage of all materials supplied by Claymark Limited or the building contractor, whether on site or off-site, is under the control of the building contractor. A-lign® weatherboards must be stacked flat, clear of the ground by a minimum of 150 mm and supported on timber bearers at maximum 900 mm centres. They must be kept dry at all times either by storing within an enclosed building or when stored externally an additional secondary cover to the plastic wrapping is required. Care must be taken to avoid damage to edges, ends and the primed surfaces. Weatherboards must always be carried on edge.
- 5.2 Accessories must be stored so they are kept clean, dry and undamaged. All accessories must be used within the maximum storage period recommended by the manufacturer.

Technical Literature

- 6.1 Refer to the Appraisals listing on the BRANZ website for details of the current Technical Literature for the A-lign® Rusticated Weatherboard Cavity Cladding Solution. The Technical Literature must be read in conjunction with this Appraisal. All aspects of design, use, installation and maintenance contained in the Technical Literature and within the scope of this Appraisal must be followed.

Design Information

Framing

Timber Treatment

- 7.1 Timber wall framing behind the A-lign® Rusticated Weatherboard Cavity Cladding Solution must be treated as required by NZBC Acceptable Solution B2/AS1.

Timber Framing

- 7.2 Timber framing must comply with NZS 3604 for buildings or parts of buildings within the scope limitations of NZS 3604. Buildings or parts of buildings outside the scope of NZS 3604 must be to a specific design in accordance with NZS 3603 and AS/NZS 1170. Where specific design is required, the framing must be of at least equivalent stiffness to the framing provisions of NZS 3604. In all cases studs must be at maximum 600 mm centres. Dwargs must be fitted flush between the studs at maximum 800 mm centres. Refer to Paragraphs 17.2 and 17.3 for information relating to the installation of the A-lign® structural cavity battens.
- 7.3 Additional framing may be required at soffits, internal and external corners and window and door openings for the support and fixing of cavity battens and the A-lign® Rusticated Weatherboard Cavity Cladding Solution.
- 7.4 Timber wall framing behind where weatherboards are joined over a cavity batten must be nominal 50 mm thickness [i.e. 45 mm minimum finished thickness].
- 7.5 Timber wall framing and A-lign® structural cavity battens must have a maximum moisture content of 20% at the time of the cladding application.
- 7.6 Timber wall framing and A-lign® structural cavity battens must have a maximum moisture content of 18% before the weatherboards are painted.

General



- 8.1 When the A-lign® Rusticated Weatherboard Cavity Cladding Solution is used for specifically designed buildings up to 2.5 kPa design differential ULS wind pressure, only the weathertightness aspects of the cladding and maximum framing centres are within the scope of this Appraisal. All other aspects of the building need to be specifically designed and are outside the scope of this Appraisal.
- 8.2 Punchings in the cavity vent strip must provide a minimum ventilation opening area of 1000 mm² per lineal metre of wall in accordance with the requirements of NZBC Acceptable Solution E2/AS1, Paragraph 9.1.8.3 [b].
- 8.3 The ground clearance to finished floor levels as set out in NZS 3604 must be adhered to at all times. At ground level paved surfaces, such as footpaths, must be kept clear of the bottom edge of the cladding solution by a minimum of 100 mm, and unpaved surfaces by 175 mm in accordance with the requirements of NZBC Acceptable Solution E2/AS1, Table 18.
- 8.4 At balcony, deck or roof/wall junctions, the bottom edge of the A-lign® Rusticated Weatherboard Cavity Cladding Solution must be kept above the top surface of any adjacent roof flashing by a minimum of 35 mm in accordance with NZBC Acceptable Solution E2/AS1, Paragraph 9.1.3.
- 8.5 All external walls of buildings must have barriers to airflow in the form of interior linings with all joints stopped for wind zones up to and including Very High, and rigid underlays for buildings in the Extra High wind zone and specifically designed buildings up to 2.5 kPa design differential ULS wind pressure. Unlined gables and walls must incorporate a rigid sheathing or an air barrier which meets the requirements of NZBC Acceptable Solution E2/AS1, Table 23. For attached garages, wall underlays must be selected in accordance with NZBC Acceptable Solution E2/AS1, Paragraph 9.1.3.4. Where rigid underlays are used, the cavity batten fixing lengths must be increased by a minimum of the thickness of the underlay.
- 8.6 Where cladding penetrations are wider than the cavity batten spacing, allowance must be made for airflow between adjacent cavities by leaving a minimum gap of 10 mm between the bottom of the cavity and the flashing to the opening.
- 8.7 Where the solution abuts other cladding solutions, designers must detail the junction to meet their own requirements and the performance requirements of the NZBC. Some guidance is given within the Technical Literature. Details not included within the Technical Literature have not been assessed and are outside the scope of this Appraisal.

Inter-storey Junctions

- 8.8 Inter-storey drained joints must be constructed in accordance with the Technical Literature. Inter-storey drained joints must be provided to limit continuous cavities to the lesser of 2-storeys or 7 metres in height, in accordance with the requirements of NZBC Acceptable Solution E2/AS1, Paragraph 9.1.9.4 [b].

Structure

Mass

- 9.1 The mass of the A-lign® Rusticated Weatherboard Cavity Cladding Solution is approximately 15 kg/m² at equilibrium moisture content. The solution is therefore considered a lightweight cladding in terms of NZS 3604.

Impact Resistance

- 9.2 The A-lign® Rusticated Weatherboard Cavity Cladding Solution has good resistance to impact loads likely to be encountered in normal residential use. The likelihood of impact damage to the solution when used in light commercial situations should be considered at the design stage, and appropriate protection such as the installation of bollards and barriers should be considered for vulnerable areas.

Wind Zones

- 9.3 The A-lign® Rusticated Weatherboard Cavity Cladding Solution is suitable for use in all Wind Zones of NZS 3604, up to and including Extra High where buildings are designed to meet the requirements of NZBC Acceptable Solution E2/AS1, Paragraph 1.1, or up to 2.5 kPa design differential ULS wind pressure where buildings are specifically designed.
- 9.4 When used on buildings situated in Building Wind Zones of NZS 3604, up to and including Very High, the A-lign® rusticated weatherboards must be fixed to the structural cavity battens with 60 x 2.8 mm hot-dip galvanised or stainless steel ring shank jolt head nails. When used on buildings situated in NZS 3604 Wind Zone Extra High and specific design wind pressures up to a design differential ultimate limit state [ULS] of 2.5 kPa, the A-lign® rusticated weatherboards must be fixed to the structural cavity battens with 75 x 3.15 mm hot-dip galvanised or stainless steel ring shank jolt head nails.

Durability

- 10.1 The A-lign® Rusticated Weatherboard Cavity Cladding Solution meets the performance requirements of NZBC Clause B2.3.1 (b), 15 years for the A-lign® weatherboards and flashings, and the performance requirements of NZBC Clause B2.3.1 (c), 5 years for the exterior paint system.

Serviceable Life

- 10.2 A-lign® Rusticated Weatherboard Cavity Cladding Solution installations are expected to have a serviceable life of at least 50 years provided the solution is maintained in accordance with this Appraisal, and the A-lign® weatherboards and fixings are continuously protected by a weathertight coating and remain dry in service. For the A-lign® Rusticated Weatherboard Cavity Cladding Solution to achieve a serviceable life of 50 years, it must be painted as soon as practicable following weatherboard and trim installation.
- 10.3 Coastal locations can be very corrosive to fasteners, especially locations within distances of up to 500 metres from the sea including harbours, or 100 metres from tidal estuaries and sheltered inlets, and otherwise as shown in NZS 3604, Figure 4.2. These coastal locations are defined in NZS 3604 as Zone D. To achieve a 50 year serviceable life in Zone D, A-lign® weatherboards must be fixed with stainless steel fasteners. Fasteners outside Zone D may be hot-dip galvanised steel.
- 10.4 Microclimatic conditions, including geothermal hot spots, industrial contamination and corrosive atmospheres, and contamination from agricultural chemicals or fertilisers can convert mildly corrosive atmosphere into aggressive environments for fasteners. The fixing of A-lign® cavity battens and weatherboards in areas subject to microclimatic conditions requires specific design in accordance with NZS 3604, Paragraph 4.2.4, and is outside the scope of this Appraisal.

Maintenance

- 11.1 Regular maintenance is essential to ensure the performance requirements of the NZBC are continually met and to ensure the maximum serviceability of the solution.
- 11.2 Regular cleaning (at least annually) of the paint coating is required to remove grime, dirt and organic growth and to maximise the life and appearance of the coating. Grime may be removed by brushing with a soft brush, warm water and detergent. Paint systems must be recoated at approximately 7 – 10 yearly intervals in accordance with the paint manufacturer's instructions.
- 11.3 Annual inspections must be made to ensure that all aspects of the cladding solution, including the paint coating solution, flashings and any sealed joints remain in a weatherproof condition. Any damaged areas or areas showing signs of deterioration which would allow water ingress must be repaired immediately. Sealant and paint coatings must be repaired in accordance with the relevant manufacturer's instructions.
- 11.4 Minimum ground clearances as set out in this Appraisal and the Technical Literature must be maintained at all times during the life of the solution. *[Failure to adhere to the minimum ground clearances given in this Appraisal and the Technical Literature will adversely affect the long term durability of the A-lign® Rusticated Weatherboard Cavity Cladding Solution.]*



Control of External Fire Spread

- 12.1 The A-lign® Rusticated Weatherboard Cavity Cladding Solution has not been assessed for a peak heat release or total heat released rating.
- 12.2 Refer to NZBC Acceptable Solutions C/AS1 and C/AS2 and Verification Method C/VM2 for requirements for fire rating and exterior surface finish requirements of external walls.

Prevention of Fire Occurring

- 13.1 Separation or protection must be provided to the A-lign® Rusticated Weatherboard Cavity Cladding Solution from heat sources such as fire places, heating appliances, flues and chimneys. Part 7 of NZBC Acceptable Solutions C/AS1 and C/AS2 and NZBC Verification Method C/VM1 provide methods for separation and protection of combustible materials from heat sources.

External Moisture

- 14.1 The A-lign® Rusticated Weatherboard Cavity Cladding Solution, when installed in accordance with this Appraisal and the Technical Literature will prevent the penetration of moisture that could cause undue dampness or damage to building elements.
- 14.2 The cavity must be sealed off from the roof and sub-floor space to meet code compliance with NZBC Clause E2.3.5.
- 14.3 The A-lign® Rusticated Weatherboard Cavity Cladding Solution allows excess moisture present at the completion of construction to be dissipated without permanent damage to building elements to meet code compliance with Clause E2.3.6.
- 14.4 The details given in the Technical Literature for weather sealing are based on the principle of having a first and second line of defence against moisture entry for all joints, penetrations and junctions. The ingress of moisture must be excluded by detailing joinery and wall interfaces as shown in the Technical Literature. Weathertightness details that are developed by the designer are outside the scope of this Appraisal and are the responsibility of the designer for compliance with the NZBC.
- 14.5 The A-lign® Rusticated Weatherboard Cavity Cladding Solution, where there is a designed cavity drainage path for moisture that penetrates the cladding, does not reduce the requirements for junctions, penetrations, etc to remain weather resistant.

Internal Moisture

Water Vapour

- 15.1 The A-lign® Rusticated Weatherboard Cavity Cladding Solution is not a barrier to the passage of water vapour, and when installed in accordance with this Appraisal will not create a risk of moisture damage resulting from condensation.

Installation Information

Installation Skill Level Requirements

- 16.1 Installation must always be carried out in accordance with the A-lign® Rusticated Weatherboard Cavity Cladding Solution Technical Literature and this Appraisal by, or under the supervision of, a Licensed Building Practitioner [LBP] with the relevant Licence Class.
- 16.2 Installation of the accessories supplied by the building contractor must be carried out in accordance with the A-lign® Rusticated Weatherboard Cavity Cladding Solution Technical Literature and this Appraisal by, or under the supervision of, a Licensed Building Practitioner [LBP] with the relevant Licence Class.



A-lign® Solution Installation

Building Underlay and Flexible Sill and Jamb Tape Installation

- 17.1 The selected building underlay and flexible sill and jamb tape system must be installed by the building contractor in accordance with the underlay and tape manufacturer's instructions prior to the installation of the cavity battens and the rest of the A-lign® Rusticated Weatherboard Cavity Cladding Solution. Flexible building underlay must be installed horizontally and be continuous around corners. Underlay must be lapped 75 mm minimum at horizontal joints and 150 mm minimum over studs at vertical joints. Generic rigid sheathing materials must be installed in accordance with NZBC Acceptable Solution E2/AS1 and be overlaid with a flexible wall underlay. Proprietary systems shall be installed in accordance with the manufacturer's instructions. Particular attention must be paid to the installation of the building underlay and sill and jamb tapes around window and door openings to ensure a continuous seal is achieved and all exposed wall framing in the opening is protected.

A-lign® Structural Cavity Batten Installation

- 17.2 The A-lign® structural cavity battens must be installed over the building wrap to the wall framing at maximum 600 mm centres where the studs are at 600 mm centres or at 400 mm centres when studs are at 400 mm centres. The cavity battens must be fixed in place with 60 x 2.8 mm hot-dip galvanised or stainless steel ring shank jolt head driven nails or 64 x 2.8 mm stainless steel ring shank power driven nails at 300 mm centres. The nail fixings must be staggered 12 mm either side of the batten centre line. Refer to BRANZ Bulletin Number 582 for further information.
- 17.3 Where studs are at greater than 450 mm centres and a flexible wall underlay is being used, a building underlay support must be installed over the underlay at maximum 300 mm centres horizontally.

A-lign® Rusticated Weatherboard Installation

- 17.4 A-lign® weatherboards may be cut on site by power or hand saw. Holes and cut-outs may be formed by using a hole saw.
- 17.5 A-lign® weatherboards must be dry prior to installation. Before the weatherboards are installed, cut ends must be sealed with A-lign® End Seal, or with two coats of premium timber primer.
- 17.6 A-lign® weatherboards must be installed starting at the bottom of the wall. The bottom course of weatherboards or the base board must overhang the bottom plate by a minimum of 50 mm.
- 17.7 Before the weatherboards are installed, the corner detail must be prepared to suit the selected option, i.e. external box corner or mitred corner. The necessary flashings must be installed before commencing weatherboard fixing and the Quickflash cavity closure must be installed continuously around the bottom of all cavities.
- 17.8 A-lign® weatherboards must be overlapped 25 mm with a minimum 2 mm gap at the overlap between boards. A A-lign® pre-cut scribe or storey rod must be used to ensure the weatherboards are accurately set out.
- 17.9 Fix each weatherboard with one nail per board at every cavity batten. Fixing must be carried out using 60 x 2.8 mm or 75 x 3.15 mm hot-dip galvanised or stainless steel ring shank jolt head nails depending on the wind zone and corrosion zone – see Paragraphs 9.4 and 10.3. The fixing must be located 40 mm above the bottom edge of the overlap board, be located no closer than 32 mm from the end of the board and be punched a maximum of 2 mm below the surface of the board. Start fixing the weatherboards at the middle of their length and work outwards to the ends. Pre-drill all fixings within 50 mm of the end of the board.
- 17.10 Fix weatherboards in full lengths where possible. Where joints are unavoidable, scarf the weatherboard at 45° over a cavity batten and fix with one fixing through the overlapping board. Prime the cut ends of all scarf joints with A-lign® End Seal aerosol primer, or with two coats of premium timber primer before fixing.



Aluminium Joinery Installation

- 17.11 Aluminium joinery and associated head flashings must be installed by the building contractor in accordance with the Technical Literature. A 7.5 – 10 mm nominal gap must be left between the joinery reveal and the wall framing so a PEF rod and air seal can be installed after the joinery has been secured in place.
- 17.12 After installing the window and door joinery, A-lign® facing boards, planted sills and scribes may be installed in accordance with the Technical Literature to provide additional weatherproofing for the joinery/weatherboard junction.

Finishing

- 17.13 To prevent swelling of the weatherboard around the punched fixing, the fixing must be filled immediately, or alternatively the weatherboard and the head of the fixing must be primed with a premium timber primer.
- 17.14 The paint coating manufacturer's instructions must be followed at all times for application of the paint finish. A-lign® rusticated weatherboards must be painted as soon as practicable following fixing and must be clean and dry before commencing. If A-lign® weatherboards are exposed to the weather for more than 4 months they must be reprimed with one coat of alkyd primer prior to the application of the finishing coats. Allow the recommended drying time between coats and follow the temperature limitations for application.

Inspection

- 17.15 The Technical Literature must be referred to during the inspection of A-lign® Rusticated Weatherboard Cavity Cladding Solution installations.

Basis of Appraisal

The following is a summary of the technical investigations carried out:

Tests

- 18.1 The following testing has been completed by BRANZ:
- BRANZ expert opinion on NZBC E2 code compliance for A-lign® Rusticated Weatherboard Cavity Cladding Solution was based on testing and evaluation of all details within the scope and as stated within this Appraisal. The A-lign® Rusticated Weatherboard Cavity Cladding Solution details were tested to E2/VM1. The testing assessed the performance of the foundation detail, window head, jamb and sill details, vertical and horizontal weatherboard joints, internal and external corners. In addition to the weathertightness test, the details contained within the Technical Literature have been reviewed, and an opinion has been given by BRANZ technical experts that the solution will meet the performance levels of Acceptable Solution E2/AS1 for cavity-based weatherboard claddings.
 - Fastener pull-through testing. BRANZ determined design wind suction pressures, and by comparing these pressures with AS/NZS 1170 pressure coefficients, the fixing requirements were determined for timber framed walls.

Other Investigations

- 19.1 Structural and durability opinions have been provided by BRANZ technical experts.
- 19.2 The performance and testing of rusticated weatherboard wall cladding products in New Zealand and Australia has been considered, including the structural and weathertightness performance, durability and non-hazardous nature.
- 19.3 Site visits have been carried out by BRANZ to assess the practicability of installation and to examine completed installations.
- 19.4 The Technical Literature for the A-lign® Rusticated Weatherboard Cavity Cladding Solution has been examined by BRANZ and found to be satisfactory.



Quality

- 20.1 The manufacture of A-lign® weatherboards has been examined by BRANZ, including methods adopted for quality control. Details regarding the quality and composition of the materials used were obtained by BRANZ and found to be satisfactory.
- 20.2 The quality of materials, components and accessories supplied by Claymark Limited is the responsibility of Claymark Limited. The quality control system for the finger jointing of A-lign® weatherboards and accessories has been assessed and registered as meeting the requirements of AS 5069.
- 20.3 The quality control system for the timber treatment of A-lign® weatherboards, cavity battens and accessories has been assessed and registered as meeting the requirements of a timber treatment quality assurance programme.
- 20.4 Quality of installation on site of components and accessories supplied by Claymark Limited and the building contractor is the responsibility of the installer.
- 20.5 Designers are responsible for the building design, and building contractors are responsible for the quality of installation of framing solutions and joinery, building underlay, flashing tapes, airseals and the A-lign® Rusticated Weatherboard Cavity Cladding Solution in accordance with the instructions of Claymark Limited.
- 20.6 Building owners are responsible for the maintenance of the A-lign® Rusticated Weatherboard Cavity Cladding Solution in accordance with the instructions of Claymark Limited.

Sources of Information

- AS 3730: 2006 Guide to the properties of paints for buildings.
- AS 5069: 2006 Timber – Finger jointing in non-structural products – Product requirements.
- AS/NZS 1170: 2002 Structural design actions.
- AS/NZS 4534:2006 Zinc and zinc/aluminium-alloy coatings on steel wire.
- AS/NZS 4680:2006 Hot-dip galvanized [zinc] coatings on fabricated ferrous articles.
- NZS 3603:1993 Timber Structures Standard.
- NZS 3604:2011 Timber-framed buildings.
- NZS 4211:2008 Specification for performance of windows.
- BRANZ Bulletin Number 411, April 2001, Recommended Timber Cladding Profiles.
- BRANZ Bulletin Number 582, April 2015, Structurally Fixed Cavity Battens.
- Ministry of Business, Innovation and Employment Record of amendments - Acceptable Solutions, Verification Methods and handbooks.
- The Building Regulations 1992.



BRANZ Appraised
Appraisal No. 638 [2019]

BRANZ Appraisal
Appraisal No. 638 [2019]
13 August 2019

A-LIGN® RUSTICATED
WEATHERBOARD CAVITY
CLADDING SOLUTION



In the opinion of BRANZ, the **A-lign® Rusticated Weatherboard Cavity Cladding Solution** is fit for purpose and will comply with the Building Code to the extent specified in this Appraisal provided it is used, designed, installed and maintained as set out in this Appraisal.

The Appraisal is issued only to **Claymark Limited**, and is valid until further notice, subject to the Conditions of Appraisal.

Conditions of Appraisal

1. This Appraisal:
 - a) relates only to the product as described herein;
 - b) must be read, considered and used in full together with the Technical Literature;
 - c) does not address any Legislation, Regulations, Codes or Standards, not specifically named herein;
 - d) is copyright of BRANZ.
2. **Claymark Limited**:
 - a) continues to have the product reviewed by BRANZ;
 - b) shall notify BRANZ of any changes in product specification or quality assurance measures prior to the product being marketed;
 - c) abides by the BRANZ Appraisals Services Terms and Conditions;
 - d) warrants that the product and the manufacturing process for the product are maintained at or above the standards, levels and quality assessed and found satisfactory by BRANZ pursuant to BRANZ's Appraisal of the product.
3. BRANZ makes no representation or warranty as to:
 - a) the nature of individual examples of, batches of, or individual installations of the product, including methods and workmanship;
 - b) the presence or absence of any patent or similar rights subsisting in the product or any other product;
 - c) any guarantee or warranty offered by **Claymark Limited**.
4. Any reference in this Appraisal to any other publication shall be read as a reference to the version of the publication specified in this Appraisal.
5. BRANZ provides no certification, guarantee, indemnity or warranty, to **Claymark Limited** or any third party.

For BRANZ

Chelydra Percy
Chief Executive
Date of Issue:
00 Month Year