



BRANZ Appraised

Appraisal No. 852 [2019]

SIKAPROOF® A WATERPROOFING MEMBRANE

Appraisal No. 852 [2019]

This Appraisal Replaces BRANZ
Appraisal 852[2014]



BRANZ Appraisals

Technical Assessments of
products for building and
construction.



BUILDING TRUST

Sika [NZ] Ltd

PO Box 19 192

Avondale

Auckland 1746

Tel: 0800 SIKA NZ

Fax: 0800 SIKA FAX

Web: www.sika.co.nz



BRANZ

BRANZ

1222 Moonshine Rd,

RD1, Porirua 5381

Private Bag 50 908

Porirua 5240,

New Zealand

Tel: 04 237 1170

branz.co.nz

Product

- 1.1 SikaProof® A Waterproofing Membrane is a flexible polyolefin (FPO) sheet for use as a pre-applied membrane for waterproofing and tanking structural concrete floors and walls.

Scope

- 2.1 SikaProof® A Waterproofing Membrane has been appraised for use as a waterproofing membrane within the following scope:
 - on building subject to specific design with in-situ structural concrete floors and walls complying with NZS 3101; and,
 - where the membrane may be subjected to hydrostatic pressure and that pressure does not exceed the equivalent of a 15 m [1.5 bar] head of water.
- 2.2 The product must be installed by Sika [NZ] Ltd approved applicators.

Building Regulations

New Zealand Building Code (NZBC)

- 3.1 **In the opinion of BRANZ, SikaProof® A Waterproofing Membrane if designed, used, installed and maintained in accordance with the statements and conditions of this Appraisal, will meet the following provisions of the NZBC:**

Clause B2 DURABILITY: Performance B2.3.1 [a] not less than 50 years. SikaProof® A Waterproofing Membrane meets this requirement. See Paragraph 11.1.

Clause E2 EXTERNAL MOISTURE: Performance E2.3.3. SikaProof® A Waterproofing Membrane meets this requirement. See Paragraphs 13.1 and 13.2.

Clause F2 HAZARDOUS BUILDING MATERIALS: Performance F2.3.1. SikaProof® A Waterproofing Membrane meets this requirement and will not present a health hazard to people





Technical Specification

4.1 Materials supplied by Sika [NZ] Ltd are as follows:

- **SikaProof® A Waterproofing Membrane** - is a pre-applied, flexible polyolefin (FPO) membrane with a grid pattern of sealant, non-woven fleece backing on the upper face and a self adhesive strip along one edge. It is supplied in a roll 1.2 mm thick, 1.0 or 2.0 m wide x 30 m long.
- **SikaProof® Tape-150A** - is a self-adhesive tape 150 mm wide for internal sealing and jointing of all detailing and transverse/cross joints
- **SikaProof® Ex Tape-150A** - is a self-adhesive tape 150 mm wide for external jointing with split release liner.
- **SikaProof® A -12 Edge** - prefabricated L-shaped edge membrane in 1 m widths for installation at edges and corners.
- **SikaProof® Patch-200** - externally applied self-adhesive membrane in 200 mm widths for additional post-construction sealing of joints, penetrations or damaged to the membrane.
- **SikaProof® MetalSheet** - laminated metal sheet for sealing around pile head penetrations.
- **SikaProof® Fix Tape-150** - tape strip in 50 mm widths for temporary repair and for internal repair of local damage.
- **SikaBit® S-515** - is a self adhesive, bituminous sheet used for detailing where the pre-applied SikaProof®A cannot be used. It is supplied as a black membrane in 1.00 m wide x 20 m long rolls.

Handling and Storage

5.1 Handling and storage of all materials whether on or off site is under the control of the installer. Dry storage must be provided for all products and the membranes must be protected from sunlight and ultra-violet (UV) radiation. Rolls of membrane must be stored on end.

Technical Literature

6.1 Refer to the Appraisals listing on the BRANZ website for details of the current Technical Literature for SikaProof® A Waterproofing Membrane. The Technical Literature must be read in conjunction with this Appraisal. All aspects of design, use, installation and maintenance contained in the Technical Literature and within the scope of this Appraisal must be followed.

Design Information

General

- 7.1 SikaProof A Waterproofing Membrane is for use as a waterproofing membrane for structural concrete floors and walls. It is pre-applied to surfaces before the fixing of reinforcing steel and before concreting. For floors the membrane is applied to site concrete. For walls the membrane is applied to either permanent formwork or removable double face formwork.
- 7.2 SikaProof® A Waterproofing Membrane is installed so that cast in-situ concrete or shotcrete is applied directly to the membrane.

Structural Concrete Floors

8.1 The membrane must be laid on a minimum of 50 mm thickness of site concrete. The structural concrete slab placed over the membrane must be a minimum of 100 mm thick.

Structural Concrete Walls

9.1 The surface to which the membrane is applied must be sound and solid to eliminate movement during the pouring of concrete. Following the removal of double faced formwork after concreting special protection sheets must be used over the membrane to provide protection before backfilling takes place. In the case of permanent formwork, the formwork must protect the membrane throughout its serviceable life. Where this is not concrete the advice of Sika [NZ] Ltd should be sought.



Control Joints

- 10.1 Where control or construction joints are formed in the substrate, Sika [NZ] Ltd must be consulted for use of the membrane at these joints.

Durability

Serviceable Life

- 11.1 SikaProof® A Waterproofing Membrane is expected to have a serviceable life of at least 50 years provided it is installed and maintained in accordance with this Appraisal and is continually protected from sunlight and ultra-violet (UV) radiation.

Maintenance

- 12.1 Annual inspections must be made of the membrane's top edge seal and protection.

External Moisture

- 13.1 SikaProof® A Waterproofing Membrane, when installed in accordance with this Appraisal and the Technical Literature, will prevent water vapour from penetrating to the interior face of basement retaining walls and floors in spaces where moisture may cause damage. The membrane has a vapour flow resistance of not less than 90 MN s/g.
- 13.2 The membrane has self-adhesive joints and tapes that can be used to form sealed joints and to seal penetrations. The top edge of the membrane must be sealed to the wall as set out in the Technical Literature and protected.

Installation Information

Installation Skill Level Requirement

- 14.1 Installation of the membranes must be completed by Sika [NZ] Ltd approved applicators in accordance with the Technical Literature and this Appraisal.

Installation

General

- 15.1 Concrete and other surfaces to which the membrane is to be applied must have a smooth and uniform finish, be dry and be free from loosely adhering material, sharp protrusions, dust, oil and grease. The advice of Sika [NZ] Ltd should be sought regarding suitable substrates and installation temperatures.

Procedure

- 15.2 The pre-formed SikaProof® A Edge Sheet is installed to all perimeters, edges, terminations and connections. The corners are formed with pre-formed SikaProof® A Edge Sheet and adhered externally with pre-formed SikaProof® Ex Tape-150A and internal with pre-formed SikaProof® Tape-150A.
- 15.3 The membrane is laid on the horizontal and vertical surfaces with the joints adhered with the self-adhesive edge strips lengthways with a minimum overlap of 90 mm. For cross joints the SikaProof® Tape-150A and SikaProof® Ex Tape-150A are used.
- 15.4 The reinforcement is fixed after the membrane has been applied, followed by applying shotcrete or concrete.
- 15.5 Special protection sheets must be used where backfilling follows to prevent damage to the membrane.

Repair

- 15.6 Any exposed fixings must be patched with tape.
- 15.7 Damage to the membrane must be repaired with tape prior to the pouring of concrete and in the case of removable formwork prior to backfilling.



Inspections

- 15.8 The Technical Literature and Sika [NZ] Ltd approved applicators Quality Control sheets must be referred to during the inspection of the membrane installation.

Health and Safety

- 16.1 Safe use and handling procedures for the membranes are provided in the Technical Literature.

Basis of Appraisal

The following is a summary of the technical investigations carried out:

Tests

- 17.1 The following testing of SikaProof® A Waterproofing Membrane has been undertaken by various organisation for watertightness, tear resistance, joint strength, impact resistance, tensile strength, resistance to static load, watertightness after artificial ageing, watertightness against chemicals, coating continuity, dimensions, thickness, straightness, mass per unit area, tensile strength, strain resistance, nail tear resistance and seam shear resistance. Test methods and results have been reviewed by BRANZ and found to be satisfactory.

Other Investigations

- 18.1 A durability opinion has been given by BRANZ technical experts.
18.2 Practicability of installation has been assessed by BRANZ and found to be satisfactory.
18.3 The Technical Literature has been examined by BRANZ and found to be satisfactory.

Quality

- 19.1 The manufacture of SikaProof® A Waterproofing Membrane has not been examined by BRANZ, but details regarding the quality and composition of the materials used were obtained by BRANZ and found to be satisfactory. BRANZ has taken note of the product certifications covering quality aspects associated with this product.
19.2 The quality of materials supplied to the market is the responsibility of Sika [NZ] Ltd.
19.3 Quality of installation on site is the responsibility of the Sika [NZ] Ltd approved applicator.
19.4 Designers are responsible for the building design, and building contractors are responsible for the quality of construction of substrate systems in accordance with the instructions of Sika [NZ] Ltd.
19.5 Building owners are responsible for the maintenance of the membrane system in accordance with the instructions of Sika [NZ] Ltd.

Sources of Information

- NZS 3101: 2006 Concrete structures standard.
- Ministry of Business, Innovation and Employment Record of amendments - Acceptable Solutions, Verification Methods and handbooks.
- The Building Regulations 1992.



BRANZ Appraised
Appraisal No. 852 [2019]

BRANZ Appraisal
Appraisal No. 852 [2019]
09 May 2019

SIKAPROOF® A WATERPROOFING
MEMBRANE



In the opinion of BRANZ, **SikaProof® A Waterproofing Membrane** is fit for purpose and will comply with the Building Code to the extent specified in this Appraisal provided it is used, designed, installed and maintained as set out in this Appraisal.

The Appraisal is issued only to **Sika [NZ] Ltd**, and is valid until further notice, subject to the Conditions of Appraisal.

Conditions of Appraisal

1. This Appraisal:
 - a) relates only to the product as described herein;
 - b) must be read, considered and used in full together with the Technical Literature;
 - c) does not address any Legislation, Regulations, Codes or Standards, not specifically named herein;
 - d) is copyright of BRANZ.
2. **Sika [NZ] Ltd**:
 - a) continues to have the product reviewed by BRANZ;
 - b) shall notify BRANZ of any changes in product specification or quality assurance measures prior to the product being marketed;
 - c) abides by the BRANZ Appraisals Services Terms and Conditions;
 - d) warrants that the product and the manufacturing process for the product are maintained at or above the standards, levels and quality assessed and found satisfactory by BRANZ pursuant to BRANZ's Appraisal of the product.
3. BRANZ makes no representation or warranty as to:
 - a) the nature of individual examples of, batches of, or individual installations of the product, including methods and workmanship;
 - b) the presence or absence of any patent or similar rights subsisting in the product or any other product;
 - c) any guarantee or warranty offered by **Sika [NZ] Ltd**.
4. Any reference in this Appraisal to any other publication shall be read as a reference to the version of the publication specified in this Appraisal.
5. BRANZ provides no certification, guarantee, indemnity or warranty, to **Sika [NZ] Ltd** or any third party.

For BRANZ

Chelydra Percy

Chief Executive

Date of Issue:

09 May 2019